



Product Service

# Attestation of Conformity

No. N8A 116618 0005 Rev. 01

**Holder of Attestation:** **Amperfiel GmbH**Gutenbergring 20  
69190 Walldorf  
GERMANY**Product:** **AC electric vehicle charging station**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 713267590**Date,** 2023-03-01

( Bernd Kreitmeier )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 116618 0005 Rev. 01

**Model(s):** Wallbox connect.home  
Wallbox connect.business

Variant	5 m cable	7,5 m cable
Wallbox connect.home (Standard)	00.779.2795	00.779.2963
Wallbox connect.home (Customer specific)*	40.020.300 to 40.020.399	
Wallbox connect.business (Standard)	00.779.2964	00.779.2965
Wallbox connect.home (Customer specific)*	40.020.400 to 40.020.499	

\*: The customer-specific variants are technically based on the standard variants. A distinction is only made with regard to the printing on the panel. The panel material is identical.

A part number range is pre-reserved for the customer-specific variants, see above. In future, a customer-specific orifice plate and one of the available cable lengths (5m, 7.5m) will be assigned under one of the pre-reserved numbers.

## Parameters:

230 / 400 V AC, 50 Hz, 3P+N+PE, max. 16 A, -25 to +40°C, IP54, IK08

**Tested according to:** EN IEC 61851-1:2019

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

